



Most Widely Accepted and Trusted

ICC-ES Evaluation Report

ESR-1170

ICC-ES | (800) 423-6587 | (562) 699-0543 | www.icc-es.org

Reissued 06/2017
This report is subject to renewal 06/2018.

DIVISION: 03 00 00—CONCRETE
SECTION: 03 21 00—REINFORCING STEEL

REPORT HOLDER:

NELSON STUD WELDING, INC.

7900 WEST RIDGE ROAD
ELYRIA, OHIO 44036

EVALUATION SUBJECT:

NELSON PUNCHING SHEAR RESISTOR STUDS



Look for the trusted marks of Conformity!

“2014 Recipient of Prestigious Western States Seismic Policy Council (WSSPC) Award in Excellence”



A Subsidiary of

ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report.



ICC-ES Evaluation Report

ESR-1170

Reissued June 2017

Revised October 2017

This report is subject to renewal June 2018.

www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

DIVISION: 03 00 00—CONCRETE
Section: 03 21 00—Reinforcing Steel

REPORT HOLDER:

NELSON STUD WELDING, INC.
7900 WEST RIDGE ROAD
ELYRIA, OHIO 44036
(440) 329-0400
www.nelsonstud.com

EVALUATION SUBJECT:

NELSON PUNCHING SHEAR RESISTOR STUDS

1.0 EVALUATION SCOPE

Compliance with the following codes:

- 2015, 2012, 2009 and 2006 *International Building Code*® (IBC)
- 2013 *Abu Dhabi International Building Code* (ADIBC)[†]

For evaluation for compliance with codes adopted by Los Angeles Department of Building and Safety (LADBS), see ESR-1170 [LABC and LARC Supplement](#).

[†]The ADIBC is based on the 2009 IBC. 2009 IBC code sections referenced in this report are the same sections in the ADIBC.

Property evaluated:

Structural

2.0 USES

Nelson punching shear resistor (PSR) studs are large-headed shear studs that are welded to steel plates (or steel base rails) to form headed shear stud reinforcement assemblies, which are used as shear reinforcement in flat concrete slabs to replace stirrups, drop panels or column capitals in increasing the punching shear resistance of the slabs.

3.0 DESCRIPTION

Nelson punching shear resistor (PSR) studs are provided in $\frac{3}{8}$ -, $\frac{1}{2}$ -, $\frac{5}{8}$ - and $\frac{3}{4}$ -inch (9.5, 12.7, 15.9 and 19.1 mm) diameters and comply with the material requirements and specifications of ASTM A1044-05(2010). The studs are made from ASTM A29 Grades 1010 through 1020 steel satisfying the following physical requirements according to ASTM A1044:

- Yield strength: 51,000 psi (350 MPa), minimum.

- Tensile strength: 65,000 psi (450 MPa), minimum.
- Elongation: 20 percent in 2 inches (51 mm), minimum.
- Reduction of area: 50 percent, minimum.

Figure 1 shows the stud configuration. The dimensions of the studs are shown in Table 1.

4.0 INSTALLATION AND DESIGN

The end use of the PSR studs, including the manufacture of headed shear stud reinforcement products, is outside the scope of this report and must be addressed in a separate ICC-ES evaluation report showing compliance with the ICC-ES Acceptance Criteria for Headed Shear Stud Reinforcement Assemblies for Concrete Slabs and Footings (AC395).

5.0 CONDITIONS OF USE

The Nelson Punching Shear Resistor Studs described in this report comply with, or are suitable alternatives to what is specified in, those codes listed in Section 1.0 of this report, subject to the condition that installation and design of the finished assemblies is in accordance with Section 4.0 of this report.

6.0 EVIDENCE SUBMITTED

- 6.1 Product specifications and drawings in accordance with ASTM A1044.
- 6.2 Weld base qualification tests in accordance with AWS D1.1-2010.
- 6.3 Quality documentation in accordance with the ICC-ES Acceptance Criteria for Quality Documentation (AC10).

7.0 IDENTIFICATION

Nelson PSR studs are identified by the name "Nelson" and the letter "N" on the head of each stud, and are shipped in packaging bearing the company name (Nelson Stud Welding, Inc.), the evaluation report number (ESR-1170), the stud description, the part number, the heat number, the lot number and the number of pieces in each package. Certificates of compliance with AWS D1.1:2010, and certified mill test reports on the steel used to form the studs, must be supplied by Nelson for each stud shipment.

TABLE 1—PSR STUD DIMENSIONS

STUD SHANK DIAMETER, D [inch (mm)]	HEAD DIAMETER, H [inch (mm)]	$\frac{H}{D}$	SHANK AREA, S_A [inch ² (mm ²)]	HEAD AREA, H_A [inch ² (mm ²)]	$\frac{H_A}{S_A}$	HEAD THICKNESS, T [inch (mm)]
³ / ₈ (9.5)	1.19 (30.1)	3.17	0.110 (71)	1.112 (712)	10.1	0.24 (6.1)
¹ / ₂ (12.7)	1.58 (40.2)	3.16	0.196 (127)	1.961 (1269)	10.0	0.33 (8.4)
⁵ / ₈ (15.9)	1.98 (50.2)	3.17	0.307 (199)	3.079 (1979)	10.0	0.40 (10.2)
³ / ₄ (19.1)	2.37 (60.2)	3.16	0.442 (287)	4.412 (2846)	10.0	0.47 (12.0)




FIGURE 1—PSR STUD CONFIGURATION

ICC-ES Evaluation Report

ESR-1170 LABC and LARC Supplement

Issued November 2017

This report is subject to renewal June 2018.

www.icc-es.org | (800) 423-6587 | (562) 699-0543 A Subsidiary of the International Code Council®

DIVISION: 03 00 00—CONCRETE
Section: 03 21 00—Reinforcing Steel

REPORT HOLDER:

NELSON STUD WELDING, INC.
7900 WEST RIDGE ROAD
ELYRIA, OHIO 44036
(440) 329-0400
www.nelsonstud.com

EVALUATION SUBJECT:

NELSON PUNCHING SHEAR RESISTOR STUDS

1.0 REPORT PURPOSE AND SCOPE

Purpose:

The purpose of this evaluation report supplement is to indicate that Nelson Punching Shear Resistor Studs, described in ICC-ES master evaluation report [ESR-1170](#), have also been evaluated for compliance with the codes noted below as adopted by the Los Angeles Department of Building and Safety (LADBS).

Applicable code editions:

- 2017 *City of Los Angeles Building Code* (LABC)
- 2017 *City of Los Angeles Residential Code* (LARC)

2.0 CONCLUSIONS

The Nelson Punching Shear Resistor Studs, described in Sections 2.0 through 7.0 of the master evaluation report [ESR-1170](#), comply with the LABC Chapter 19, and the LARC, and are subjected to the conditions of use described in this supplement.

3.0 CONDITIONS OF USE

The Nelson Punching Shear Resistor Studs described in this evaluation report must comply with all of the following conditions:

- All applicable sections in the master evaluation report [ESR-1170](#).
- The design, installation, conditions of use and identification of the Nelson Punching Shear Resistor Studs are in accordance with the 2015 *International Building Code*® (2015 IBC) provisions noted in the master evaluation report [ESR-1170](#).
- The design, installation and inspection are in accordance with additional requirements of LABC Chapters 16 and 17, as applicable.
- Under the LARC, an engineered design in accordance with LARC Section R301.1.3 must be submitted.

This supplement expires concurrently with the master report, issued June 2017 and revised October 2017.